

# UKCA Certificate of Constancy of Performance

This is to certify that:

Argus Security Srl  
Via del Canneto, 14  
Valle delle Noghere  
Muggia  
Trieste  
34015  
Italy

Holds Certificate Number:

0086 CPR 746295

In respect of:

## **BS EN 54-17: 2005 & BS EN 54-18: 2005 Short Circuit Isolator & Input / Output Devices**

In compliance with the Regulation (UK) Statutory Instrument 2019 No 465 of the United Kingdom Parliament (Construction Products (Amendment etc.) (EU Exit) Regulations or CPR), this certificate applies to the above construction product. This certificate attests that all the provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the above standard(s) under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product. This certificate was first issued on the date below and will remain valid as long as neither the designated standard, the construction product, the AVCP methods, nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the approved product certification body.

For and on behalf of BSI, an Approved Body for the above Regulation (Approved Body Number 0086):

Frank Lee, Product Certification Technical and Compliance Director

First Issued: 2021-10-12

Effective Date: 2021-10-12

Latest Issue: 2021-10-12

Page: 1 of 4

...making excellence a habit.™

# UKCA Certificate of Constancy of Performance

No. 0086 CPR 746295

Manufacturing Plant: **Argus Security Srl**  
Via del Canneto, 14  
Valle delle Noghere  
Muggia  
Trieste  
34015  
Italy

**Short Circuit Isolators and Input / Output Devices – BS EN 54-17:2005+AC:2007  
and BS EN 54-18:2005+AC:2007.**

## Product Information

Model Reference	Type
VMCZ100	CONVENTIONAL ZONE MODULE
VMIC422	ANALOGUE 4 IN / 2 OUT SUP / 2 OUT REL
VMIC404	ANALOGUE 4 IN / 4 OUT REL
VMIC602	ANALOGUE 6 IN / 2 OUT REL
VMDIC404	ANALOGUE DIN RAIL 4 IN / 4 OUT REL

First Issued: 2021-10-12  
Latest Issue: 2021-10-12

Effective Date: 2021-10-12

Page: 2 of 4

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.  
To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

BSI Assurance UK Limited, registered in England under number 7805321 at 389 Chiswick High Road, London W4 4AL, UK.  
A member of BSI Group of Companies.

# UKCA Certificate of Constancy of Performance

No. 0086 CPR 746295

## Appendix 1

Harmonised Technical Specification		BS EN 54-17:2005
Essential Characteristics	Performance	Clause
<b>Performance under fire conditions</b>		
Reproducibility	Pass	5.2
<b>Operational Reliability</b>		
Requirements	Pass	4
<b>Durability of Operational Reliability</b>		
Dry heat	Pass	5.4
Cold (operational)	Pass	5.5
Damp heat, cyclic (operational)	Pass	5.6
Damp heat, steady state (endurance)	Pass	5.7
Sulphur dioxide (SO <sub>2</sub> ) corrosion	Pass	5.8
Shock (operational)	Pass	5.9
Impact (operational)	Pass	5.10
Vibration, sinusoidal (operational)	Pass	5.11
Vibration, sinusoidal (endurance)	Pass	5.12
<b>Durability of Operational Reliability, Electrical Stability</b>		
Variation in supply parameters	Pass	5.3
Electromagnetic compatibility (EMC), immunity tests (operational)	Pass	5.13

First Issued: 2021-10-12

Effective Date: 2021-10-12

Latest Issue: 2021-10-12

Page: 3 of 4

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.  
To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

BSI Assurance UK Limited, registered in England under number 7805321 at 389 Chiswick High Road, London W4 4AL, UK.  
A member of BSI Group of Companies.

# UKCA Certificate of Constancy of Performance

No. 0086 CPR 746295

## Appendix 1 (continued)

Harmonised Technical Specification		BS EN 54-18:2005
Essential Characteristics	Performance	Clause
<b>Response Delay (response time)</b>		
Performance and variation of supply parameters	Pass	5.2
<b>Performance under fire conditions</b>		
Functional test	Pass	5.1.4
<b>Operational Reliability</b>		
Functional test	Pass	5.1.4
<b>Durability of Operational Reliability</b>		
Dry heat	Pass	5.3
Cold (operational)	Pass	5.4
Damp heat, cyclic (operational)	Pass	5.5
Damp heat, steady state (endurance)	Pass	5.6
Sulphur dioxide (SO <sub>2</sub> ) corrosion	Pass	5.7
Shock (operational)	Pass	5.8
Impact (operational)	Pass	5.9
Vibration, sinusoidal (operational)	Pass	5.10
Vibration, sinusoidal (endurance)	Pass	5.11
<b>Durability of Operational Reliability, Electrical Stability</b>		
Performance and variation of supply parameters	Pass	5.2
Electromagnetic compatibility (EMC), immunity tests (operational)	Pass	5.12

First Issued: 2021-10-12

Effective Date: 2021-10-12

Latest Issue: 2021-10-12

Page: 4 of 4

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.  
To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

BSI Assurance UK Limited, registered in England under number 7805321 at 389 Chiswick High Road, London W4 4AL, UK.  
A member of BSI Group of Companies.