

BRE Global

UK Approved Body No. 0832

BRE Global Limited
Bucknalls Lane, Garston, Watford,
Hertfordshire, UK, WD25 9XX
Telephone: +44 (0) 333 321 8811
Fax: +44 (0)1923 664603
Email: enquiries@breglobal.com
Web: www.breglobal.com

Certificate of UKCA approval constancy of performance 0832-UKCA-CPR-F0505

In compliance with the Construction Product Regulations 2020, UK Statutory Instruments 2020 No.1359 of Ministry of Housing, Communities and Local Government. This certificate applies to the construction product.

CWS100 Conventional Type A/B (Indoor/Outdoor) Wall Sounder (Red Body)

(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trademark of: and produced in the manufacturing plant(s):

Argus Security S.r.l
Via del Canneto 14
Valle delle Noghere
34015 Muggia
Trieste
Italy

Argus Security S.r.l
Via del Canneto 14
Valle delle Noghere
34015 Muggia
Trieste
Italy

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 54-3: 2001 + A1: 2002 + A2: 2006 Sounders

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

the constancy of performance of the construction product.

This certificate was first issued on 08 November 2021 and will remain valid as long as neither the designated standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the approved product certification body.



P. Halligan, Technical Manager

On behalf of BRE Global Limited

Date of First Issue: 08 November 2021

Issue Date: 08 November 2021

Issue Number: 01

To check the validity of this certificate, please contact us on +44 (0)333 321 8811 or email enquiries@breglobal.com

BRE Global**UK Approved Body No. 0832**

BRE Global Limited
Bucknalls Lane, Garston, Watford,
Hertfordshire, UK, WD25 9XX
Telephone: +44 (0) 333 321 8811
Fax: +44 (0)1923 664603
Email: enquiries@breglobal.com
Web: www.breglobal.com

APPENDIX to Certificate of constancy of performance: 0832-UKCA-CPR-F0505**CWS100 Conventional Type A/B (Indoor/Outdoor) Wall Sounder (Red Body)**

Notes:

1. Meets the requirements of EN 54-3 at the following tone settings:
Tone 1 - Warble Tone 800Hz for 500ms, then 1000Hz for 500ms
Tone 2 – Continuous Tone, 970Hz
Tone 3 – Slow Whoop (Dutch), 500-1200Hz for 3500ms, then off for 500ms
Tone 4 – German DIN Tone, 1200-500Hz swept every 1000ms (1Hz)
2. Variant - CWS100(W) (White Body)



P. Halligan, Technical Manager

On behalf of BRE Global Limited

Date of First Issue: 08 November 2021

Issue Date: 08 November 2021

Issue Number: 01

To check the validity of this certificate, please contact us on +44 (0)333 321 8811 or email enquiries@breglobal.com