Certificate No.: 8504-UKCA-CPR-UKCSP10098



CERTIFICATE OF CONSTANCY OF PERFORMANCE

Issued by DBI Certification-UK, approved body No. 8504.

In compliance with UK STATUTORY INSTRUMENT 2020 No. 1359 Construction Products Regulation 2011 (retained EU law EUR 305/2011) as amended by the Construction Products (Amendment etc.) (EU Exit) Regulations 2019 and the Construction Products (Amendment etc.) (EU Exit) Regulations 2020, this certificate applies to the construction product

The product fulfils the essential characteristic:

	See Annex 1
Intended use:	Applications related to automatic fire alarm systems
Placed on the market under the name	or trade mark of: Argus Security S.r.I.
	Via del Canneto 14 IT-34015 Muggia (Trieste)
and produced in the manufacturing pl	ant:
	UKCPA10005
Authorized Representative:	Halma UK DS LTD
	Misbourne Court, Rectory Way Amersham, Bucks HP7 0DE
	United Kingdom

This attests that all provisions concerning the performance described in Annex ZA of the standard(s)

EN 54-17:2005	:	Fire detection and fire alarm systems — Part 17: Short circuit isolators
EN 54-18:2005	:	Fire detection and fire alarm systems — Part 18: Input/output devices

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

CONSTANCY OF PERFORMANCE OF THE CONSTRUCTION PRODUCT.

This certificate was first issued on 2022-06-29 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

The attached annexes form part of this certificate.

Date of issue: 2022-06-29.

Merete Poulsen Responsible for evaluation

em

Steen Nilsson Responsible for certification decision

DBI Certification-UK Ltd. Unit 1 & 2, Northcot Park, Station Road, Blockley, Gloucestershire GL56 9LH E-mail: info@dbicertification.co.uk · www.dbicertification.co.uk



Certificate No.: 8504-UKCA-CPR-UKCSP10098



Annex 1

EXTENT

Product description:

VMIC422 Input/Output Device and Short-Circuit Isolator

Performance

Essential characteristics	Clauses in EN 54-17:2005	Performance
Performance under fire conditions	5.21)	Pass
Operational reliability	4	Pass
Durability of operational reliability; temperature resistance	5.4, 5.5	Pass
Durability of operational reliability; vibration resistance	5.9 to 5.12	Pass
Durability of operational reliability; humidity resistance	5.6, 5.7	Pass
Durability of operational reliability; corrosion resistance	5.8	Pass
Durability of operational reliability;	5.3, 5.13	Pass
electrical stability 1) This is assuming that the effect of the	e fire is to cause a short circuit in the transm	nission path that is protected by these
electrical stability 1) This is assuming that the effect of the devices		
electrical stability 1) This is assuming that the effect of the devices Essential characteristics	Clauses in EN 54-18:2005	Performance
electrical stability 1) This is assuming that the effect of the devices Essential characteristics Response delay (response time)	Clauses in EN 54-18:2005 5.2 ¹⁾	Performance Pass
electrical stability 1) This is assuming that the effect of the devices Essential characteristics Response delay (response time) Performance under fire conditions	Clauses in EN 54-18:2005 5.2 ¹⁾ 5.1.4	Performance Pass Pass
electrical stability 1) This is assuming that the effect of the devices Essential characteristics Response delay (response time) Performance under fire conditions Operational reliability	Clauses in EN 54-18:2005 5.2 ¹⁾	Performance Pass
electrical stability 1) This is assuming that the effect of the devices Essential characteristics Response delay (response time) Performance under fire conditions Operational reliability Durability of operational reliability; temperature resistance	Clauses in EN 54-18:2005 5.2 ¹⁾ 5.1.4 5.1.4 5.3, 5.4	Performance Pass Pass Pass Pass
electrical stability 1) This is assuming that the effect of the devices Essential characteristics Response delay (response time) Performance under fire conditions Operational reliability Durability of operational reliability;	Clauses in EN 54-18:2005 5.2 ¹⁾ 5.1.4 5.1.4	Performance Pass Pass Pass Pass
electrical stability 1) This is assuming that the effect of the devices Essential characteristics Response delay (response time) Performance under fire conditions Operational reliability Durability of operational reliability; temperature resistance Durability of operational reliability; vibration resistance Durability of operational reliability;	Clauses in EN 54-18:2005 5.2 ¹⁾ 5.1.4 5.1.4 5.3, 5.4	Performance Pass Pass Pass Pass Pass
electrical stability 1) This is assuming that the effect of the devices Essential characteristics Response delay (response time) Performance under fire conditions Operational reliability Durability of operational reliability; temperature resistance Durability of operational reliability;	Clauses in EN 54-18:2005 5.2 ¹⁾ 5.1.4 5.1.4 5.3, 5.4 5.8 to 5.11	Performance Pass Pass Pass Pass Pass Pass

1) Response delays may not be a function of the input/output device, in which case no assessment is made as part of this standard

Annex 2

TEST DOCUMENTATION

Test documentation can be found in case no. UKCSP10098-001.

Annex 3

TECHNICAL BASIS

File Number	Title	Date
BOM-VM422-0003 (VMIC422)	Vega Multimodule - Standard Box version 4 Input 2 Relay Output 2 Supervised Output Module (VMIC422) - Bill of Material	2022-03-25, Rev. E

DBI Certification-UK Ltd.

Unit 1 & 2, Northcot Park, Station Road, Blockley, Gloucestershire GL56 9LH E-mail: info@dbicertification.co.uk \cdot www.dbicertification.co.uk

