

BRE Global Ireland

Notified Body No. 2831
BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland
T: +353 (0) 18824344
E: enquiries@breglobalireland.ie
www.breglobalireland.ie

Certificate of constancy of performance

2831-CPR-F2649

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

ALCP100- Altair Type A Indoor Addressable Manual Call Point with Short Circuit Isolator

(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trade mark of:

and produced in the manufacturing plant(s):

Argus Security Srl
Via del Canneto 14
Valle delle Noghere
34015, Muggia
Trieste
Italy

Argus Security Srl
Via del Canneto 14
Valle delle Noghere
34015, Muggia
Trieste
Italy

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 54-11: 2001 + A1: 2005 – Manual Call Points
EN 54-17: 2005 – Short Circuit Isolators

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

the constancy of performance of the construction product.

This certificate was first issued on 24 March 2020 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.



P Halligan, Certification Engineer

Date of First Issue: 24 March 2020

Date of Issue: 24 March 2020

On behalf of BRE Global Assurance (Ireland) Limited

Issue number 01

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie

BRE Global Ireland

Notified Body No. 2831

BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland

T: +353 (0) 18824344

E: enquiries@breglobalireland.ie

www.breglobalireland.ie

APPENDIX to Certificate of constancy of performance: 2831-CPR-F2649

ALCP100- Altair Type A Indoor Addressable Manual Call Point with Short Circuit Isolator

Ancillaries

ALCI -Transparent hinged cover
FMP-303 Flush Fitting Bezel



P Halligan, Certification Engineer,

On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 24 March 2020

Date of issue: 24 March 2020

Issue number: 01

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie