

## BRE Global Ireland

**Notified Body No. 2831**  
BRE Global Assurance (Ireland) Limited  
DCU Alpha, Old Finglas Road  
Glasnevin, Dublin, D11 KXN4  
Ireland  
T: +353 (0) 18824344  
E: [enquiries@breglobalireland.ie](mailto:enquiries@breglobalireland.ie)  
[www.breglobalireland.ie](http://www.breglobalireland.ie)

## Certificate of constancy of performance

### 2831-CPR-F0626

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

#### A2000 Addressable Multi-Criteria Detector with Short Circuit Isolator

(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trade mark of:

and produced in the manufacturing plant(s):

**Argus Security S.r.l**  
**Via del Canneto 14**  
**Valle delle Noghere**  
**34015 Muggia**  
**Trieste**  
**Italy**

**Argus Security S.r.l**  
**Via del Canneto 14**  
**Valle delle Noghere**  
**34015 Muggia**  
**Trieste**  
**Italy**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

**EN 54-5:2000 + A1:2002 - Heat detectors - Point detectors**  
**EN 54-7:2000 + A1:2002 + A2:2006 - Smoke detectors - Point detectors**  
**EN 54-17:2005 - Short circuit isolators**

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

### **the constancy of performance of the construction product.**

This certificate was first issued on 17 October 2019 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.



P. Halligan, Certification Engineer

Date of First Issue: 17 October 2019

Date of Issue: 17 October 2019

On behalf of BRE Global Assurance (Ireland) Limited

Issue number 01

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email [enquiries@breglobalireland.ie](mailto:enquiries@breglobalireland.ie).

**BRE Global Ireland**

**Notified Body No. 2831**

BRE Global Assurance (Ireland) Limited  
DCU Alpha, Old Finglas Road  
Glasnevin, Dublin, D11 KXN4  
Ireland  
T: +353 (0) 18824344  
E: [enquiries@breglobalireland.ie](mailto:enquiries@breglobalireland.ie)  
[www.breglobalireland.ie](http://www.breglobalireland.ie)

**APPENDIX to Certificate of constancy of performance: 2831-CPR-F0626**

**A2000 Addressable Multi-Criteria Detector with Short Circuit Isolator**

**Notes:**

1. Meets the requirements of EN 54-5 (Class A1) & EN 54-7 at the following settings:  
Multi Criteria Level 1 (most sensitive) - Thermally enhanced smoke detection with Class A1 heat response  
Multi Criteria Level 2 - Thermally enhanced smoke detection with Class A1 heat response  
Multi Criteria Level 3 - Thermally enhanced smoke detection with Class A1 heat response  
Multi Criteria Level 4 (least sensitive) - Thermally enhanced smoke detection with Class A1 heat response
2. Meets the requirements of EN 54-5 (Class A1R) at the following settings:  
Class A1R heat only response
3. Meets the requirements of EN 54-7 at the following sensitivity settings:  
Optical only level 1 - High  
Optical only level 2  
Optical only level 3  
Optical only level 4 – Low

**Base:**

LAB1000 Standard mounting base



P. Halligan, Certification Engineer,

On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 17 October 2019

Date of issue: 17 October 2019

Issue number: 01

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email [enquiries@breglobalireland.ie](mailto:enquiries@breglobalireland.ie).