



CERTIFICATE OF CONSTANCY OF PERFORMANCE

0051 – CPR – 0653

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation, or CPR), this Certificate applies to the construction product

SOUNDER ALARM DEVICE

Trademark: **ARGUS SECURITY**
Model: **AI-BS-01; AC-BS-01; VC-BS-01**

Other information: **see ANNEX**

Produced by:
ARGUS SECURITY S.r.l.
Via Del Canneto, 14 – 34015 Muggia (TS)

In the manufacturing plant:
PI.L000BW

This Certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

EN 54-3:2001 + A1:2002 + A2:2006

under system **1** are applied and that **the product fulfills all the prescribed requirements set out above.**

This certificate cancels and replaces the certificate having the same number and issued on 2017-07-31 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonized standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.

ING. V. BAGGIO
CPR TECHNICAL DIRECTOR

Milan, 2020-10-07

This Certificate was issued by IMQ S.p.A., a Notified Body according to Regulation (EU) No. 305/2011.
IMQ S.p.A. Identification Number is: 0051.

ANNEX

0051 – CPR – 0653

General characteristics

Destination of use: Type A (indoor use)

Degrees of protection: IP21C

EN 54-3 Certified tones:

Tone 1: Warble Tone – 800-1000 Hz, 1 Hz;

Tone 2: Continuous Tone – 970 Hz;

Tone 3: Slow Whoop (NL) – 500-1200 Hz for 3.5 s ON 0.5 s OFF;

Tone 4: German DIN tone – 1200-500 Hz, 1Hz.

Technical characteristic:

- Main board (PCB code No. SBN00-00A);
- Hardware Identification (U1): trademark TI type MSP430G2433IPW28;
- Firmware Identification (U1): 1.3.3;
- Piezo trademark KAILITECH type KD-50B-29EW80.