

**CERTIFICATE OF CONSTANCY OF PERFORMANCE**

Issued by DBI Certification-UK, approved body No. 8504.

In compliance with UK STATUTORY INSTRUMENT 2020 No. 1359 Construction Products Regulation 2011 (retained EU law EUR 305/2011) as amended by the Construction Products (Amendment etc.) (EU Exit) Regulations 2019 and the Construction Products (Amendment etc.) (EU Exit) Regulations 2020, this certificate applies to the construction product

**TW-BS-01, TW-BS-01/BL**

The product fulfils the essential characteristic:

**See Annex 1**

Intended use:

Applications related to automatic fire alarm systems

Placed on the market under the name or trade mark of:

**Argus Security S.r.l.  
Via del Canneto 14  
34015 Muggia (Trieste)  
Italy**

and produced in the manufacturing plant:

**UKCPA10005**

Authorized Representative:

**Halma UK DS LTD  
Misbourne Court, Rectory Way  
Amersham, Bucks HP7 0DE  
United Kingdom**

This attests that all provisions concerning the performance described in Annex ZA of the standard(s)

**EN 54-3:2001+A1:2002+A2:2006 : Fire detection and fire alarm systems — Part 3: Fire alarm devices — Sounders**

**EN 54-25:2008+AC:2012 : Fire detection and fire alarm systems — Part 25: Components using radio links**

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

**CONSTANCY OF PERFORMANCE OF THE CONSTRUCTION PRODUCT.**

This certificate was first issued on 2022-04-29 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

The attached annexes form part of this certificate.

Date of issue: **2022-08-03.**

(This certificate supersedes the previous version of this certificate issued 2022-04-29)



Merete Poulsen  
Responsible for evaluation



Steen Nilsson  
Responsible for certification decision

**DBI Certification-UK Ltd.**

Unit 1 & 2, Northcot Park, Station Road, Blockley, Gloucestershire GL56 9LH  
E-mail: info@dbicertification.co.uk · www.dbicertification.co.uk



No. 23333

Annex 1

EXTENT

**Product description:**

TW-BS-01 Sounder using Radio Links  
 TW-BS-01/BL Sounder using Radio Links

**Configuration**

The sounder models TW-BS-01 and TW-BS-01/BL (Black colour version) consists of a plastic enclosure (dimensions: 129 (d) x 55 (h) mm) with IP21C degree of protection, containing:

- No. 1 Main board (PCB code B40-TWBSX-0002)
- No. 1 Piezoelectric buzzer (trademark Kingstate, model KBIG5010N08028AZ)
- No. 2 Battery allocable (CR123A Lithium, 3 V – 1.25Ah)
- 

**Technical Characteristics**

Tone patterns in compliance with EN 54-3:

- Warble Tone: 800 Hz for 500 ms then 1000 Hz for 500 ms
- Continuous tone: 970 Hz continuous
- Slow Whoop (Dutch): 500-1200 Hz for 3500 ms, then off for 500 ms
- German DIN tone: 1200-500Hz swept every 1000 ms (1Hz)

Destination for use: Type A (for internal)

Operating frequency band: 868 MHz 916 MHz

Hardware identification of the microcontroller (U4 and U5) used on the main board:

- Texas Instruments, MSP430G2433 (U4)
- STMicroelectronics, STM32L051K86 (U5)

Firmware identification of the microcontroller (U4 and U5) used on the main board:

- 1\_0\_1 (U4) 0\_1\_14 (U5), using the 868 MHz frequency band
- 1\_0\_1 (U4) 0\_1\_14 (U5), using the 916 MHz frequency band

**Performance**

Essential characteristics	Clauses in EN 54-3:2001+A1:2002+A2:2006	Performance
Performance under fire conditions	4.2, 4.3, 5.2, 5.3	Pass
Operational reliability	4.4, 4.5, 4.6, 5.4	Pass
Durability of operational reliability and response delay; temperature resistance	5.5, 5.7, 5.8, 5.9	Pass
Durability of operational reliability; humidity resistance	5.8, 5.9	Pass
Durability of operational reliability; corrosion resistance	5.11	Pass
Durability of operational reliability; vibration resistance	5.12 to 5.15	Pass
Durability of operational reliability; electrical stability	5.16	Pass
Durability of operational reliability; resistance to ingress	5.17	Pass
5.16 applies only to sounders or voice sounders with active electronic components		

**DBI Certification-UK Ltd.**

Unit 1 & 2, Northcot Park, Station Road, Blockley, Gloucestershire GL56 9LH  
 E-mail: info@dbicertification.co.uk · www.dbicertification.co.uk



No. 23333

Essential characteristics	Clauses in EN 54-25:2008+AC:2012	Performance
Performance parameters under fire conditions	4.1, 4.2.2, 5.2, 8.3.7	Pass
Response delay (response time to fire)	8.2.3, 8.2.6	Pass
Operational reliability	4.2.1, 4.2.3 to 4.2.7, 5.3, 5.4, 6, 7, 8.2.2, 8.2.4, 8.2.5, 8.2.7, 8.2.8, 8.2.9, 8.3.1, 8.3.2, 8.3.3, 8.3.4, 8.3.5, 8.3.6	Pass
Durability of operational reliability and response delay; temperature resistance	8.3.9, 8.3.10, 8.3.11	Pass
Durability of operational reliability; vibration resistance	8.3.16, 8.3.17 to 8.3.19	Pass
Durability of operational reliability; humidity resistance	8.3.12, 8.3.13, 8.3.14	Pass
Durability of operational reliability; corrosion resistance	8.3.15	Pass
Durability of operational reliability; electrical stability	8.3.20	Pass

**Annex 2**

**TEST DOCUMENTATION**

Test documentation can be found in case no. UKCSP10086.

**Annex 3**

**TECHNICAL BASIS**

File Number	Title	Date
BOM-TWBSX-0002	TAURUS WIRELESS BASE SOUNDER (TW-BS-01) - 868 / 916 VARIANTS - Bill of Material	2021-12-27, Rev. M