Certificate No.: 8504-UKCA-CPR-UKCSP10088



CERTIFICATE OF CONSTANCY OF PERFORMANCE

Issued by DBI Certification-UK, approved body No. 8504.

In compliance with UK STATUTORY INSTRUMENT 2020 No. 1359 Construction Products Regulation 2011 (retained EU law EUR 305/2011) as amended by the Construction Products (Amendment etc.) (EU Exit) Regulations 2019 and the Construction Products (Amendment etc.) (EU Exit) Regulations 2020, this certificate applies to the construction product

TW-MI-S-01

The product fulfils the essential characteristic:

See Annex 1

Intended use: Applications related to automatic fire alarm systems

Placed on the market under the name or trade mark of:

Argus Security S.r.l. Via del Canneto 14 IT-34015 Muggia (Trieste)

and produced in the manufacturing plant:

UKCPA10005

Authorized Representative:

Halma UK DS LTD Misbourne Court, Rectory Way Amersham, Bucks HP7 ODE

United Kingdom

This attests that all provisions concerning the performance described in Annex ZA of the standard(s)

EN 54-18:2005 : Fire detection and fire alarm systems — Part 18: Input/output devices

EN 54-25:2008+AC:2012 : Fire detection and fire alarm systems — Part 25: Components using radio links

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

CONSTANCY OF PERFORMANCE OF THE CONSTRUCTION PRODUCT.

This certificate was first issued on 2022-04-29 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

The attached annexes form part of this certificate.

Date of issue: 2022-04-29.

Merete Poulsen Responsible for evaluation Steen Nilsson
Responsible for certification decision

DBI Certification-UK Ltd.

 $\label{localization} \begin{tabular}{ll} Unit 1 \& 2, Northcot Park, Station Road, Blockley, Gloucestershire GL56 9LH E-mail: info@dbicertification.co.uk \\ \cdot www.dbicertification.co.uk \\ \end{tabular}$

No. 23333

Certificate No.: 8504-UKCA-CPR-UKCSP10088



Annex 1

EXTENT

Product description:

TW-MI-S-01 Input Device using Radio Links

Configuration

The input device model TW-MI-S-01 consists of a plastic enclosure (dimensions: $136 \times 96 \times 57$ mm) with IP30 degree of protection, containing:

- No. 1 Main board (PCB code B40-TWMI0-0003)
- No. 2 Battery allocable (CR123A Lithium, 3 V 1.25Ah)

Technical Characteristics

Operating frequency band: 868 MHz; 916 MHz;

Hardware identification of the microcontroller (U2) used on the main board:

- STMicroelectronics, STM32L051R8

Firmware identification of the microcontroller (U2) used on the main board:

- 0_1_15, using the 868 MHz frequency band
- 0_1_16, using the 916 MHz frequency band

Performance

Essential characteristics	Clauses in EN 54-18:2005	Performance		
Response delay (response time)	5.2 ¹⁾	Pass		
Performance under fire conditions	5.1.4	Pass		
Operational reliability	5.1.4	Pass		
Durability of operational reliability;	5.3, 5.4	Pass		
temperature resistance				
Durability of operational reliability;	5.8 to 5.11	Pass		
vibration resistance				
Durability of operational reliability;	5.5, 5.6	Pass		
humidity resistance				
Durability of operational reliability;	5.7	Pass		
corrosion resistance				
Durability of operational reliability;	5.2, 5.12	Pass		
electrical stability				

¹⁾ Response delays may not be a function of the input/output device, in which case no assessment is made as part of this standard

Essential characteristics	Clauses in EN 54-25:2008+AC:2012	2 Performance	
Performance parameters under fire conditions	4.1, 4.2.2, 5.2, 8.3.7	Pass	
Response delay (response time to fire)	8.2.3, 8.2.6	Pass	
Operational reliability	4.2.1, 4.2.3 to 4.2.7, 5.3, 5.4, 6, 7, 8.2.2, 8.2.4, 8.2.5, 8.2.7, 8.2.8, 8.2.9, 8.3.1, 8.3.2, 8.3.3, 8.3.4, 8.3.5, 8.3.6	Pass	
Durability of operational reliability and response delay; temperature resistance	8.3.9, 8.3.10, 8.3.11	Pass	
Durability of operational reliability; vibration resistance	8.3.16, 8.3.17 to 8.3.19	Pass	
Durability of operational reliability; humidity resistance	8.3.12, 8.3.13, 8.3.14	Pass	
Durability of operational reliability; corrosion resistance	8.3.15	Pass	
Durability of operational reliability; electrical stability	8.3.20	Pass	

DBI Certification-UK Ltd.



Version 2022-02-08 Page **2** of **3**

Certificate No.: 8504-UKCA-CPR-UKCSP10088



Annex 2

TEST DOCUMENTATION

Test documentation can be found in case no. UKCSP10088-001.

Annex 3

TECHNICAL BASIS

ECHNICAL BASIS								
File	Number			Title			Date	
BOM-TWMI	S-0005		ELESS MODUL) - 868 / 916 M				2022-03-25, Rev. C	

DBI Certification-UK Ltd.



Version 2022-02-08 Page **3** of **3**