

Certificate of Constancy of performance

0051 – CPR – 0418

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

INPUT/OUTPUT DEVICE AND SHORT-CIRCUIT ISOLATOR

Designation: VMDIC404

Characteristics: **see ANNEX**

Produced by:

ARGUS SECURITY S.r.l.
Via del Canneto 14, 34015 Muggia, Trieste

In the manufacturing plant:

PI.L000BW


This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standards

EN 54-17:2005, EN 54-18:2005

under system **1** are applied and that

the product fulfills all the prescribed requirements set out above.

This certificate was first issued on 2013-12-06 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonized standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.



IMQ
Direttore Tecnico CPR
(Ing. V. Baggio)

Milano, 2013-12-06

This certificate was issued by IMQ S.p.A., a notified body according to Regulation 305/2011/EU.
IMQ S.p.A. Identification Number is: 0051.

Mod. 727CPR/0 ENG

ANNEX – Additional Information

TO CERTIFICATE OF CONSTANCY OF PERFORMANCE n°: 0051 – CPR – 0418

Date: 2013-12-06

Technical Characteristics:

- Plastic enclosure (119 x 101 x 22,5 mm) IP30;
- I/O Board with 4 inputs and 4 outputs, Type C.
- Hardware identification: Texas Instruments type MSP430F2252;
- Software identification: VMIC404_09_03_2011_1.66.txt crc16: 0x4229

VR