



**Argus Security S.r.l.**  
Via del Canneto, 14  
34015 - Muggia (TS) - Italy  
[info@argussecurity.it](mailto:info@argussecurity.it)

## UK Declaration of Performance - DoP

Declaration in accordance to (UK) Construction Products Regulation No 305/2011

### *UK Dichiarazione di Prestazione - DoP*

Dichiarazione in conformità al regolamento sui prodotti da costruzione (Regno Unito) n. 305/2011

**N°: SG6010UK**

#### 1. Unique identification code of the product-type:

Codice di identificazione unico del prodotto-tipo:

**Product type:** Sounders Devices; Wireless

**Model Number and Description:** **SGWS-MOD + CWS100** - SAGITTARIUS Wall Sounder Module + Conventional Wall Sounder (Type B). Operating Frequency Band: 868 MHz

#### 2. Intended use/es:

Usi previsti:

**Fire Safety**

**Fire detection and fire alarm systems installed in and around buildings**

Sicurezza Antincendio

Sistemi di rivelamento ed allarme antincendio installati all'interno ed intorno agli edifici

#### 3. Manufacturer:

Fabbricante:

**ARGUS SECURITY Srl**

Via del Canneto 14

Valle delle Noghere - 34015 Muggia - Trieste - Italy

[info@argussecurity.it](mailto:info@argussecurity.it)

[www.argussecurity.it](http://www.argussecurity.it)

#### 4. Authorised representative:

Mandatario:

**Halma UK DS LTS**

Misbourne Court, Rectory Way, Amersham

Bucks HP7 0DE, UK

#### 5. System/s of AVCP:

Sistemi di VVCP:

System 1

#### 6. Designated standard(s):

Norme Indicate:

EN 54-3: 2001 + A1:2002 + A2:2006

EN 54-25: 2008 + AC:2012

#### 7. UK Approved Body/ies

Organismi Approvati dalla UK

**BSI Group – Netherlands, No. 0086**

Product code:

**SGWS-MOD +  
CWS100**CoP Reference: **0086-CPR-746290****8. Declared performance/s:****Prestazioni Dichiarate:**

ESSENTIAL CHARACTERISTICS	CLAUSE APPLICABLE	PERFORMANCE	DESIGNATED STANDARD
Performance under fire conditions	4.2, 4.3, 5.2, 5.3	PASS	EN 54-3: 2001 + A1:2002; + A2:2006
Operational reliability	4.4, 4.5, 4.6, 5.4	PASS	
Durability of operational reliability, temperature resistance	5.5, 5.7, 5.8, 5.9	PASS	
Durability of operational reliability, humidity resistance	5.8, 5.9	PASS	
Durability of operational reliability, corrosion resistance	5.11	PASS	
Durability of operational reliability, shock and vibration resistance	5.12 to 5.15	PASS	
Durability of operational reliability, electrical stability	5.16 <sup>(1)</sup>	PASS	
Durability of operational reliability, resistance to ingress	5.17	PASS	
<sup>(1)</sup> 5.16 applies only to sounders or voice sounders with active electronic components.			
ESSENTIAL CHARACTERISTICS	CLAUSE APPLICABLE	PERFORMANCE	DESIGNATED STANDARD
Performance parameters under fire conditions	4.1, 4.2.2, 5.2, 8.3.7	PASS	EN 54-25:2008
Response delay (response time to fire)	8.2.3, 8.2.6	PASS	
Operational reliability	4.2.1, 4.2.3 to 4.2.7, 5.3, 5.4, 6, 7, 8.2.2, 8.2.4, 8.2.5, 8.2.7, 8.2.8 <sup>(a)</sup> , 8.2.9, 8.3.1, 8.3.2, 8.3.3, 8.3.4, 8.3.5, 8.3.6	PASS	
Durability of operational reliability, temperature resistance	8.3.9 <sup>(b)</sup> , 8.3.10 <sup>(b)</sup> , 8.3.11	PASS	
Durability of operational reliability, vibration resistance	8.3.16 <sup>(b)</sup> , 8.3.17 to 8.3.19	PASS	
Durability of operational reliability, humidity resistance	8.3.13 <sup>(c)</sup> , 8.3.14	PASS	
Durability of operational reliability, corrosion resistance	8.3.15 <sup>(b)</sup>	PASS	
Durability of operational reliability, electrical stability	8.3.20	PASS	
The products covered by this standard are assumed to enter the alarm condition, in an event of fire, before the fire becomes so large as to affect their functioning. There is therefore no requirement to function when exposed to direct attack from fire.			
<sup>(a)</sup> Only applicable to components required to indicate loss of communication or to transmit this information to the CIE.			
<sup>(b)</sup> Not applicable for CIE			
<sup>(c)</sup> Only applicable for CIE and smoke detectors			

**The performance of the products identified in point 1 in conformity with the declared performance in the point 8. This declaration is issued under the sole responsibility of the manufacturer identified in point 3.**

La prestazione dei prodotti individuati al punto 1 è conforme alla prestazione dichiarata al punto 8. Tale dichiarazione è rilasciata sotto l'esclusiva responsabilità del fabbricante individuato al punto 3.

**This document is available on website: [www.argussecurity.it](http://www.argussecurity.it) (section download for each product)**

Questo documento è disponibile sul sito: [www.argussecurity.it](http://www.argussecurity.it) (nella sezione "download" di ogni prodotto)

**Signed for and on behalf of the manufacturer by:**

Firmato a nome e per conto del Fabbricante da:



**Technical Director  
Mauro Ceppa**

Trieste, Italy

20/11/2021