

CERTIFICATE OF CONSTANCY OF PERFORMANCE

Issued by DBI Certification-UK, approved body No. 8504.

In compliance with UK STATUTORY INSTRUMENT 2020 No. 1359 Construction Products Regulation 2011 (retained EU law EUR 305/2011) as amended by the Construction Products (Amendment etc.) (EU Exit) Regulations 2019 and the Construction Products (Amendment etc.) (EU Exit) Regulations 2020, this certificate applies to the construction product

TW-MWSO-01 + CWS100-AV (Red enclosure)
TW-MWSO-01 + CWS100-AV(W) (White enclosure)

The product fulfils the essential characteristic:

See Annex 1

Intended use: Applications related to automatic fire alarm systems

Placed on the market under the name or trade mark of:

Argus Security S.r.l. Via del Canneto 14 34015 Muggia (Trieste)

Italy

and produced in the manufacturing plant:

UKCPA10005

Authorized Representative:

Halma UK DS LTD

Misbourne Court, Rectory Way Amersham, Bucks HP7 0DE

United Kingdom

This attests that all provisions concerning the performance described in Annex ZA of the standard(s)

EN 54-3:2001+A1:2002+A2:2006 : Fire detection and fire alarm systems — Part 3: Fire alarm devices — Sounders

EN 54-23:2010 : Fire detection and fire alarm systems — Part 23: Fire alarm devices — Visual

alarm devices

EN 54-25:2008+AC:2012 : Fire detection and fire alarm systems — Part 25: Components using radio links

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

CONSTANCY OF PERFORMANCE OF THE CONSTRUCTION PRODUCT.

This certificate was first issued on 2022-04-29 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

The attached annexes form part of this certificate.

Date of issue: 2022-04-29.

Merete Poulsen Responsible for evaluation Steen Nilsson
Responsible for certification decision

DBI Certification-UK Ltd.

Version 2022-02-08

 $\label{localization} \mbox{Unit 1\& 2, Northcot Park, Station Road, Blockley, Gloucestershire $\mbox{ GL56 9LH E-mail: info@dbicertification.co.uk} \cdot \mbox{www.dbicertification.co.uk}$





Annex 1

EXTENT

Product description:

TW-MWSO-01 + CWS100-AV (Red enclosure) sounder and visual alarm device using radio links TW-MWSO-01 + CWS100-AV(W) (White enclosure) sounder and visual alarm device using radio links

Configuration:

The product consists of a red or white plastic enclosure (dimensions: 130 (d) \times 90 (h) mm) with IP33C degree of protection which contains a:

- Wireless module model TW-MW\$O-01, containing:
 - No. 1 Main board (PCB code B40-ISWSM-0002)
 - No. 2 Battery allocable (CR123A Lithium, 3 V 1.25Ah)
- Sounder and visual alarm device models CWS100-AV and CWS100-AV(W), containing
 - No. 1 Main board (PCB code B20-CWS1X-1002)
 - No. 1 Piezoelectric buzzer

Technical Characteristics:

Tone patterns in compliance with EN 54-3:

- Warble Tone: 800 Hz for 500 ms then 1000 Hz for 500 ms
- Continuous tone: 970 Hz continuous
- Slow Whoop (Dutch): 500-1200 Hz for 3500 ms, then off for 500 ms
- German DIN tone: 1200-500Hz swept every 1000 ms (1Hz)

Coverage characteristics: W2.5-7

Flash rate: 0.5 Hz

Destination for use: Type B (for external)
Operating frequency band: 868 MHz; 916 MHz

Hardware identification of the microcontroller (U5) used on the main board (PCB code B40-ISWSM-0002):

STMicroelectronics, STM32L051R8

Firmware identification of the microcontroller (U5) used on the main board (PCB code B40-ISWSM-0002):

- 0_1_12, using the 868 MHz frequency band
- 0_1_13, using the 916 MHz frequency band

List of optional functions with requirements (EN 54-23):

4.3.7 Synchronization

Performance

Essential characteristics	Clauses in EN 54-3:2001	Performance
Performance under fire conditions	4.2, 4.3, 5.2, 5.3	Pass
Operational reliability	4.4, 4.5, 4.6, 5.4	Pass
Durability of operational reliability	5.5, 5.6, 5.7, 5.8, 5.9	Pass
and response delay; temperature		
resistance		
Durability of operational reliability;	5.8, 5.9, 5.10	Pass
humidity resistance		
Durability of operational reliability;	5.11	Pass
corrosion resistance		
Durability of operational reliability;	5.12 to 5.15	Pass
vibration resistance		
Durability of operational reliability;	5.16	Pass
electrical stability		
Durability of operational reliability;	5.17	Pass
resistance to ingress		

DBI Certification-UK Ltd.

 $\label{localization} \mbox{Unit 1\& 2, Northcot Park, Station Road, Blockley, Gloucestershire $\mbox{ GL56 9LH E-mail: info@dbicertification.co.uk} \cdot \mbox{www.dbicertification.co.uk}$



No. 23333



Essential characteristics	Clauses in EN 54-23:2010	Level(s) or	Notes
		class(es)	
Operational reliability:			
Duration of operation	4.2.1		Pass
Flammability of materials	4.2.3		Pass
Enclosure protection	4.2.4		Pass
Access	4.2.5		Pass
Manufacturer's adjustments	4.2.6		Pass
Requirements for software controlled devices	4.2.8		Pass
Performance parameters under fire condition:		1	
Coverage volume	4.3.1		Pass
Variation of light output	4.3.2		Pass
Minimum and maximum light intensity	4.3.3		Pass
Light colour	4.3.4		Red/White
Light temporal pattern and frequency of flashing	4.3.5		Pass/0.5 Hz
Marking and data	4.3.6		Pass
Synchronization (option with requirements)	4.3.7		Pass
Durability:			
Temperature resistance:		None	
Dry heat (operational)	4.4.1.1		Pass
Dry heat (endurance)	4.4.1.2		Pass
Cold (operational)	4.4.1.3		Pass
Humidity resistance:			
Damp heat, cyclic (operational)	4.4.2.1		Pass
Damp heat, steady state (endurance)	4.4.2.2		Pass
Damp heat, cyclic (endurance)	4.4.2.3		Pass
Shock and vibration resistance:			
Shock (operational)	4.4.3.1		Pass
Impact (operational)	4.4.3.2		Pass
Vibration (operational)	4.4.3.3		Pass
Vibration (endurance)	4.4.3.4		Pass
Corrosion resistance:			
SO ₂ corrosion (endurance)	4.4.4		Pass
Electrical stability:			
EMC, immunity (operational)	4.4.5		Pass

Essential characteristics	Clauses in EN 54-25:2008+AC:2012	Performance
Performance parameters under fire conditions	4.1, 4.2.2, 5.2, 8.3.7	Pass
Response delay (response time to fire)	8.2.3, 8.2.6	Pass
Operational reliability	4.2.1, 4.2.3 to 4.2.7, 5.3, 5.4, 6, 7, 8.2.2, 8.2.4, 8.2.5, 8.2.7, 8.2.8, 8.2.9, 8.3.1, 8.3.2, 8.3.3, 8.3.4, 8.3.5, 8.3.6	Pass
Durability of operational reliability and response delay; temperature resistance	8.3.9, 8.3.10, 8.3.11	Pass
Durability of operational reliability; vibration resistance	8.3.16, 8.3.17 to 8.3.19	Pass
Durability of operational reliability; humidity resistance	8.3.12, 8.3.13, 8.3.14	Pass
Durability of operational reliability; corrosion resistance	8.3.15	Pass
Durability of operational reliability; electrical stability	8.3.20	Pass

DBI Certification-UK Ltd.



Page **3** of **4**



Annex 2

TEST DOCUMENTATION

Test documentation can be found in case no. UKCSP10085-001.

Annex 3

TECHNICAL BASIS

File Number	Title	Date
BOM-CWS1X-1002	CONVENTIONAL WALL SOUNDER BEACON (CWS100-AV) & WHITE VERSION CWS100-AV(W) - Bill of Material	2022-03-25, Rev. Q
BOM-TWMWS-0002	TAURUS WIRELESS WALL SOUNDER OUTPUT MODULE (TW-MWSO-01) - 868 / 916 MHz VARIANTS - Bill of Material	2021-12-27, Rev. N



DBI Certification-UK Ltd.



Version 2022-02-08 Page **4** of **4**