

Certificate of Product Approval

Certificate Number: 928c

Issue: 18

Argus Security Srl

Via del Canneto 14
Valle delle Noghere
34015 Muggia
Trieste
Italy



is certified by BRE Global Ltd. and is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

Products

Multi-Sensor/Multi Criteria Detectors

A2000

(refer to Appendix for details)

Standards

EN 54-5:2017 + A1:2018

EN 54-7:2018

EN 54-17:2005

CEA 4021:2003

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

P Halligan

Signed for BRE Global Ltd

Verifier

25 August 2022

Date of Issue

15 July 2009

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



Argus Security Srl

Certified Product	Description	LPCB Ref.No.
A2000	<p>Addressable Multi-Criteria Detector with Short Circuit Isolator (LAB1000 base)</p> <p>Notes:</p> <ol style="list-style-type: none"> Meets the requirements of EN 54-5 (Category A1) & EN 54-7 at the following settings: <ul style="list-style-type: none"> Multi Criteria Level 1 (most sensitive) - Thermally enhanced smoke detection with Category A1 heat response Multi Criteria Level 2 - Thermally enhanced smoke detection with Category A1 heat response Multi Criteria Level 3 - Thermally enhanced smoke detection with Category A1 heat response Multi Criteria Level 4 (least sensitive) - Thermally enhanced smoke detection with Category A1 heat response Meets the requirements of EN 54-5 (Category A1R) at the following settings: <ul style="list-style-type: none"> Category A1R heat only response Meets the requirements of EN 54-7 at the following sensitivity settings: <ul style="list-style-type: none"> Optical only level 1 - High Optical only level 2 Optical only level 3 Optical only level 4 - Low 	928c/02

Bases

LAB1000 Low profile adaptor base

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for BRE Global Ltd

P Halligan

Verifier

25 August 2022

Date of Issue

15 July 2009

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



Argus Security Srl

Alternative Model No./Label

LPCB Ref No.	Model No.	Alternative Model No./Label	Cross-listed company	Cross-Listed Co Cert./ Ref No.
928c/02	A2000	FF OT200A	Finder Yangin Güvenlik Elektronik Sistemler A.Ş.	928c-(cl-1)
928c/02	A2000	AT430A	Advantronic Systems S.L.	928c-(cl-3)
928c/02	A2000	HFI-MA-05	Hyfire Wireless Fire Solutions Limited	928c-(cl-9)
928c/02	A2000	TI-002213	Ceasefire Industries Private Ltd	928c-(cl-10)
928c/02	A2000	100-2401V	Eurotech Fire Systems Ltd	1213p

Bases

LPCB Ref No.	Model No.	Model No./Label	Cross-listed company	Cross-Listed Co
928	LAB1000	FF BS200A	Finder Yangin Güvenlik Elektronik Sistemler A.Ş	928
928	LAB1000	HFI-DMBS-05	Hyfire Wireless Fire Solutions Limited	928
928	LAB1000	BA400	Advantronic Systems S.L.	928
928	LAB1000	100-3000V	Eurotech Fire Systems Ltd	1213
928	LAB1000	TI-002231	Ceasefire Industries Private Ltd	928

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for BRE Global Ltd

P Halligan

Verifier

25 August 2022

Date of Issue

15 July 2009

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.


