

BRE Global Ireland

Notified Body No. 2831
BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland
T: +353 (0) 18824344
E: enquiries@breglobalireland.ie
www.breglobalireland.ie

Certificate of constancy of performance

2831-CPR-F0209

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

A2000L Altair Lite Addressable Photoelectric Smoke Detector & Category A1R Heat Detector

(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trade mark of:

and produced in the manufacturing plant(s):

Argus Security S.r.l.
Via del Canneto 14
Valle delle Noghere
34015 Muggia
Trieste
Italy

Argus Security S.r.l.
Via del Canneto 14
Valle delle Noghere
34015 Muggia
Trieste
Italy

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 54-5: 2017 + A1: 2018 Heat detectors – Point heat detectors

EN 54-7: 2018 Smoke detectors – Point smoke detectors

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

the constancy of performance of the construction product.

This certificate was first issued on 17 October 2019 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.



P. Halligan, Certification Engineer

Date of First Issue: 17 October 2019

Date of Issue: 25 August 2022

On behalf of BRE Global Assurance (Ireland) Limited

Issue number 02

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie.

BRE Global Ireland

Notified Body No. 2831

BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland
T: +353 (0) 18824344
E: enquiries@breglobalireland.ie
www.breglobalireland.ie

APPENDIX to Certificate of constancy of performance: 2831-CPR-F0209

A2000L Altair Lite Addressable Photoelectric Smoke Detector & Category A1R Heat Detector

Notes:

1. Meets the requirements of EN 54-5 (Category A1) & EN 54-7 at the following settings:
Multi criteria level 1 (most sensitive) - thermally enhanced smoke detection with Category A1 heat
Multi criteria level 2 - thermally enhanced smoke detection with Category A1 heat response
Multi criteria level 3 - thermally enhanced smoke detection with Category A1 heat response
Multi criteria level 4 (least sensitive) - thermally enhanced smoke detection with Category A1 heat
2. Meets the requirements of EN 54-5 (Category A1R) at the following sensitivity settings:
Category A1R heat only response
3. Meets the requirements of EN 54-7 at the following sensitivity settings:
Optical only - level 1 – High sensitivity
Optical only - level 2
Optical only - level 3
Optical only - level 4 – Low sensitivity

Base:

LAB1000 Low Profile Adapter Base



P. Halligan, Certification Engineer,

On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 17 October 2019

Date of issue: 25 August 2022

Issue number: 02

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie.