



Argus Security S.r.l.
Via del Canneto, 14
34015 - Muggia (TS) - Italy
info@argussecurity.it

CPR – Construction Products Regulation EU n.305/2011 Declaration of Performance – DoP

Declaration in accordance with Commission Delegated Regulation EU n.574/2014 which amends Annex III of Regulation n.305/2011

CPR – Regolamento Prodotti da Costruzione EU n.305/2011 Dichiarazione di Prestazione - DoP

Dichiarazione ai sensi del Regolamento Delegato UE n.574/2014 della Commissione che modifica l'Allegato III del Regolamento n.305/2011

N°: LI5310CPR

1. Unique identification code of the product-type:

Codice di identificazione unico del prodotto-tipo:

Product type: Heat Detectors; Smoke Detector with scattered light, transmitted light or ionization; Wireless

Model Number and Description: **L-OP-SG** – LIBRA Bi directional Wireless Addressable Dual Path Optical Smoke Detector with Variable Sensitivity

L-MC-SG – LIBRA Bi-directional Wireless Addressable Multicriteria Detector with Variable Sensitivity

L-HT-SG – LIBRA Bi-directional Wireless Addressable Class P Heat Detector

2. Intended use/es:

Usi previsti:

Fire Safety

Point detectors for use in fire detection and fire alarm systems installed in and around buildings

Fire detection and fire alarm systems installed in and around buildings

Sicurezza Antincendio

Rivelatori puntiformi per l'uso in sistemi di rivelamento e allarme antincendio installati all'interno ed intorno agli edifici

Sistemi di rivelamento ed allarme antincendio installati all'interno ed intorno agli edifici

3. Manufacturer:

Fabbricante:

ARGUS SECURITY Srl

Via del Canneto 14

Valle delle Noghere - 34015 Muggia - Trieste - Italy

info@argussecurity.it

www.argussecurity.it

4. Authorised representative:

Mandatario:

N/A

5. System/s of AVCP:

Sistemi di VVCP:

System 1

6. Harmonised standard(s):

Norme Armonizzate:

EN 54-5:2017 + A1:2018 (L-MC-SG; L-HT-SG)

EN 54-7:2017 (L-OP-SG; L-MC-SG)

EN 54-25:2008 (L-OP-SG; L-MC-SG; L-HT-SG)

CEA 4021:2003 (L-MC-SG)

7. Notified Body/ies:

Organismi Notificati:

Bre Global Assurance (Ireland) Ltd, No. 2831

| | | | |
|---------------|----------------|----------------|-----------------------|
| Product code: | L-OP-SG | CoP Reference: | 2831-CPR-F1303 |
| | L-MC-SG | CoP Reference: | 2831-CPR-F1304 |
| | L-HT-SG | CoP Reference: | 2831-CPR-F1302 |

8. Declared performance/s:

Prestazioni Dichiarate:

| ESSENTIAL CHARACTERISTICS | CLAUSE APPLICABLE | PERFORMANCE | REGULATORY CLASSES | HARMONISED STANDARD |
|---|-------------------|---|--------------------|------------------------|
| Operational reliability: | | | | |
| Position of heat sensitive element | 4.2.1 | The heat sensitive element(s) or at least part of it, except elements with auxiliary functions (e.g.characteristic correctors), are a distance $\geq 15\text{mm}$ from the mounting surface of the point heat detector. | | |
| Individual alarm indication | 4.2.2 | Category A1R The heat detector is provided with an integral red visual indicator and can remain identified until the alarm is reset. The visual indicator is visible from a distance of 6 m directly below the point heat detector,in an ambient light intensity up to 500 lx. | | |
| Connection of ancillary devices | 4.2.3 | Open or short circuit failures of connection to ancillary device do not prevent the correct operation of the detector | | |
| Monitoring of detachable point heat detectors | 4.2.4 | A fault condition is signaled when the detector is removed from the mounting base. | | |
| Manufacturer's adjustments | 4.2.5 | It is not possible to change the manufacture's settings except by special means (e.g. a special code or tool, or by breaking or remove a seal). | | |
| Onsite adjustments of response behavior | 4.2.6 | N/A | | |
| Software controlled detectors (when provided) | 4.2.7 | The software documentation and the software design complies supplied by the manufacturer with the requirements of this standard. | | |
| Nominal activation conditions/sensitivity: | | | | EN 54-5:2017 + A1:2018 |
| Directional dependence | 4.3.1 | The response time of the point dectetor do not unduly depend on the direction of airflow around the point heat detector. | | |
| Static response temperature | 4.3.2 | The response temperatures of the point heat detectors lie between the minimum and maximum static response temperatures, according to the category of the point heat detector in Table 1 above. | | |
| Response times from typical application temperature | 4.3.3 | The response times of the point heat detector lie between the lower and upper response time limits for the appropriate point heat detector category in Table 2 above. | | |
| Response times from 25° | 4.3.4 | The response time at 3 K min^{-1} exceeds 7 min 13 s and the response time at 20 K min^{-1} exceeds 1 min 0 s. | | |

| Response times from high ambient temperature | 4.3.5 | No alarm or fault signal was given at high ambient temperatures appropriate to the anticipated service temperatures. A1R 3 K min ⁻¹ , Lower limit, 1 min 20 s and upper limit 13 m 40 s. 20 K min ⁻¹ , Lower limit, 12 s and upper limit 2 m 20 s. | | | | |
|---|---------|--|-------------------------------------|-------------------------------------|-----|------|
| Reproducibility | 4.3.6 | The response times of the point heat detectors lie between the lower and upper response time limits specified in Table 2 above. | | | | |
| Response delay (response time): | | | | | | |
| Additional test for suffix S point heat detectors | 4.4.1 | N/A | | | | |
| Additional test for suffix R point heat detectors | 4.4.2 | Suffix R, the point heat detector maintains the response requirements of its category, in table 2 above, for high rates of rise of temperature from an initial temperature below the typical application temperature applicable to the category marked on it. | | | | |
| | | <table border="1"> <thead> <tr> <th>Point heat detector category</th> <th>Initial conditioning temperature °C</th> </tr> </thead> <tbody> <tr> <td>A1R</td> <td>5 ±2</td> </tr> </tbody> </table> | Point heat detector category | Initial conditioning temperature °C | A1R | 5 ±2 |
| | | Point heat detector category | Initial conditioning temperature °C | | | |
| A1R | 5 ±2 | | | | | |
| | | | | | | |
| Tolerance to supply voltage: | | | | | | |
| Variation in supply parameters | 4.5 | The point heat detector does not unduly depend on variation in the supply parameters and lie between the lower and upper response time limits specified in Table 2 above. | | | | |
| Durability of nominal activation conditions/Sensitivity: | | | | | | |
| temperature resistance | | | | | | |
| Cold (operational) | 4.6.1.1 | No alarm or fault signal was given during the transition to the conditioning temperature or during the period at the condition temperature A1R: 20 K min ⁻¹ was not less than 30 s and did not exceed 30 s compared with the time obtained in 4.3.6 | | | | |
| Dry heat (operational) | 4.6.1.2 | No fault signal was given on reconnection attributable to the endurance conditioning A1R: 20 K min ⁻¹ was not less than 30 s and did not exceed 30 s compared with the time obtained in 4.3.6 | | | | |
| Humidity resistance | | | | | | |
| Damp heat, cyclic (operational) | 4.6.2.1 | No alarm or fault signal was given during the conditioning. Lower temperature: (25±3) °C Upper temperature: (40±2) °C Relative humidity: At lower temperature : ≥ 95 % At upper temperature : (93 ±3) % A1R: 20 K min ⁻¹ was not less than 30 s and did not exceed 30 s compared with the time obtained in 4.3.6 | | | | |

A1R

EN 54-5:2017 +
A1:2018

| | | |
|--|---------|--|
| Damp heat, steady-state (endurance) | 4.6.2.2 | <p>No fault signal was given on reconnection attributable to the endurance conditioning.</p> <p>Conditioning Temperature: 40 ±2 °C Relative Humidity: 93 ±3 % Duration:21 days</p> <p><u>A1R</u>: 20 K min⁻¹ was not less than 30 s and did not exceed 30 s compared with the time obtained in 4.3.6 <u>BS</u>: 20 K min⁻¹ was not less than 1 min and did</p> |
| Corrosion resistance | | |
| Sulphur dioxide (SO ₂) corrosion (endurance) | 4.6.3 | <p>No fault signal was given on reconnection attributable to the endurance conditioning.</p> <p>Conditioning Temperature: 25 ±2 °C Relative Humidity: 93 ±3 % SO₂ concentration: 25 ±5 ppm (by volume) Duration :21 days</p> <p><u>A1R</u>: 20 K min⁻¹ was not less than 30 s and did not exceed 30 s compared with the time obtained in 4.3.6</p> |
| Vibration resistance | | |
| Shock (operational) | 4.6.4.1 | <p>No alarm or fault signal was given during the conditioning period or an additional 2 min.</p> <p>For specimen with a mass ≤ 4,75 kg :</p> <p>Shock pulse type: Half sine Pulse duration : 6 ms Peak acceleration: 10X (100-20M) ms⁻² (M is specimen mass in Kg) Number of directions: 6 Pulses per direction: 3</p> <p><u>A1R</u>: 20 K min⁻¹ was not less than 30 s and did not exceed 30 s compared with the time obtained in 4.3.6</p> |
| Impact (operational) | 4.6.4.2 | <p>No alarm or fault signal was given during the conditioning period or an additional 2 min.</p> <p>Conditioning: Impact energy: 1,9 ±0,1 J Hammer velocity: 1,5 ±0,13 ms⁻¹ Number of impacts: 1</p> <p><u>A1R</u>: 20 K min⁻¹ was not less than 30 s and did not exceed 30 s compared with the time obtained in 4.3.6</p> |
| Vibration, sinusoidal (operational) | 4.6.4.3 | <p>No fault signal was given during the conditioning</p> <p>Conditioning: Frequency range: 10 to 150 Hz Acceleration amplitude: 5 ms⁻²(≈0,5 gn) Number of axes : 3 Sweep rate: 1 octave min⁻¹ Number of sweep cycles: 1 per axis</p> <p><u>A1R</u>: 20 K min⁻¹ was not less than 30 s and did not exceed 30 s compared with the time obtained in 4.3.6</p> |

EN 54-5:2017 +
A1:2018

| | | | | |
|--|--------------------------|--|---------------------------|----------------------------|
| Vibration, sinusoidal (endurance) | 4.6.4.4 | No fault signal was given on reconnection attributable to the endurance conditioning. Conditioning: Frequency range: 10 to 150 Hz Acceleration amplitude: 10 ms-2(≈1,0 gn) Number of axes: 3 Sweep rate: 1 octave min-1 Number of sweep cycles: 20 per axis <u>A1R</u> : 20 K min-1 was not less than 30 s and did not exceed 30 s compared with the time obtained in 4.3.6 | | |
| Electrical stability EMC immunity (operational) | 4.6.5 | Compliance in EN 50130-4:2011 and No fault signal was given during the conditioning. <u>A1R</u> : 20 K min ⁻¹ was not less than 30 s and did not exceed 30 s compared with the time obtained in 4.3.6 | | |
| ESSENTIAL CHARACTERISTICS | CLAUSE APPLICABLE | PERFORMANCE | REGULATORY CLASSES | HARMONISED STANDARD |
| Operational reliability: | | | | |
| Individual alarm indication | 4.2.1 | The visual indicator(s) are visible from a distance of 6 m in an ambient light intensity up to 500lx. | | |
| Connection of ancillary devices | 4.2.2 | Open or short circuit failures of connection to ancillary device did not prevent the correct operation of the detector. | | |
| Monitoring of detachable detectors | 4.2.3 | A fault condition is signaled when the detector is removed from the mounting base. | | |
| Manufacturer's adjustments | 4.2.4 | It is not possible to adjust the detector settings without the use of a special tool to access into the detector or use of a code to enabling entry into the panel programming software. | | |
| On site adjustment of response behavior | 4.2.5 | The mode(s) of operation are adjustable from the Control and Indicating Equipment by use of a loop communication protocol. Access to enable mode changes is by software control of the protocol communication. | None | EN 54-7:2018 |
| Protection against the ingress of foreign bodies | 4.2.6 | The chamber is designed so that a sphere of diameter (1,3±0,05) mm cannot pass into the sensor chamber. | | |
| Response to slowly developing fires | 4.2.7 | The provision of "drift compensation" (e.g. to compensate for sensor drift due to the build-up of dirt in the detector), does not lead to a significant reduction in the detectors sensitivity to slowly developing fires. | | |
| Software controlled detectors (when provided) | 4.2.8 | The software documentation and the software design complies with the requirements of EN 54-7:2018. | | |

| | | | | |
|---|---------|---|-----------|--------------|
| Nominal activation conditions/sensitivity: | | | Threshold | EN 54-7:2018 |
| Repeatability | 4.3.1 | Ratio of response values $m_{\max}:m_{\min} \leq 1.6$ Lower response value, $m_{\max}:m_{\min} > 0.05 \text{ dB m}^{-1}$ | | |
| Directional dependence | 4.3.2 | Ratio of response values $m_{\max}:m_{\min} \leq 1.6$ Lower response value, $m_{\max}:m_{\min} > 0.05 \text{ dB m}^{-1}$ | | |
| Reproducibility | 4.3.3 | Ratio of response values $m_{\max}:m \leq 1.33$ Ratio of the response values $m_{\min} \leq 1.5$ Lower response value, $m_{\min} \geq 0.05 \text{ dB m}^{-1}$ | | |
| Response delay (response time): | | | | |
| Air movement | 4.4.1 | Ratio is > 0.0625 and < 1.60 and the point smoke detector did not emit a fault nor alarm signal during the test with aerosol-free air | | |
| Dazzling | 4.4.2 | The specimen did not emit neither an alarm nor a fault signal and Ratio of response thresholds $m_{\max}:m_{\min} \leq 1.6$ | | |
| Tolerance to supply voltage: | | | | |
| Variation in supply parameters | 4.5 | Ratio of response values $m_{\max}:m_{\min} \leq 1.6$ Lower response value, $m_{\min} \geq 0.05 \text{ dB m}^{-1}$ | | |
| Performance parameters under fire conditions: | | | | |
| Fire sensitivity | 4.6 | Evaluated as meeting the requirements of TF2 to TF5 | | |
| Durability of nominal activation conditions/Sensitivity: | | | | |
| temperature resistance | | | | |
| Cold (operational) | 4.7.1.1 | The specimen did not emit neither an alarm nor a fault signal and Ratio of response values $m_{\max}:m_{\min} < 1.6$ | | |
| Dry heat (operational) | 4.7.1.2 | The specimen did not emit neither an alarm nor a fault signal and Ratio of response values $m_{\max}:m_{\min} < 1.6$ | | |
| Humidity resistance | | | | |
| Damp heat, steady-state (operational) | 4.7.2.1 | The specimen did not emit neither an alarm nor a fault signal and Ratio of response values $m_{\max}:m_{\min} < 1.6$ | | |
| Damp heat, steady-state (endurance) | 4.7.2.2 | No fault signal, attributable to the endurance conditioning was given on reconnection of the specimen and Ratio of response values $m_{\max}:m_{\min} \leq 1.6$ | | |
| Corrosion resistance | | | | |
| Sulphur dioxide (SO ₂) corrosion (endurance) | 4.7.3 | No fault signal, attributable to the endurance conditioning was given on reconnection of the specimen and Ratio of response values $m_{\max}:m_{\min} \leq 1.6$ | | |

| | | | |
|---|---|---|----------------------------|
| Vibration resistance | | | EN 54-7:2018 |
| Shock (operational) | 4.7.4.1 | No fault signal given from the specimen during the conditioning period or the additional 2 min. and Ratio of response values $m_{max}:m_{min} \leq 1.6$ | |
| Impact (operational) | 4.7.4.2 | No fault signal given from the specimen during the conditioning period or the additional 2 min. and Ratio of response values $m_{max}:m_{min} \leq 1.6$ | |
| Vibration, sinusoidal (operational) | 4.7.4.3 | No fault signal given from the specimen during the conditioning and Ratio of response values $m_{max}:m_{min} \leq 1.6$ | |
| Vibration, sinusoidal (endurance) | 4.7.4.4 | No fault signal, attributable to the endurance conditioning was given on reconnection of the specimen and Ratio of response values $m_{max}:m_{min} \leq 1.6$ | |
| Electrical stability EMC immunity (operational) a) Electrostatic discharge (operational) b) Radiated electromagnetic fields (operational) c) Conducted disturbances (operational) d) Fast transient bursts (operational) e) Slow high energy voltage surge (operational) | 4.7.5 | No alarm or fault signal given during the conditioning and Ratio of response values $m_{max}:m_{min} \leq 1.6$ | |
| ESSENTIAL CHARACTERISTICS | CLAUSE APPLICABLE | PERFORMANCE | HARMONISED STANDARD |
| Performance parameters under fire conditions | 4.1, 4.2.2, 5.2, 8.3.7 | PASS | EN 54-25:2008 |
| Response delay (response time to fire) | 8.2.3, 8.2.6 | PASS | |
| Operational reliability | 4.2.1, 4.2.3 to 4.2.7, 5.3, 5.4, 6, 7, 8.2.2, 8.2.4, 8.2.5, 8.2.7, 8.2.8 ^(a) , 8.2.9, 8.3.1, 8.3.2, 8.3.3, 8.3.4, 8.3.5, 8.3.6 | PASS | |
| Durability of operational reliability, temperature resistance | 8.3.9 ^(b) , 8.3.10 ^(b) , 8.3.11 | PASS | |
| Durability of operational reliability, vibration resistance | 8.3.16 ^(b) , 8.3.17 to 8.3.19 | PASS | |
| Durability of operational reliability, humidity resistance | 8.3.13 ^(c) , 8.3.14 | PASS | |
| Durability of operational reliability, corrosion resistance | 8.3.15 ^(b) | PASS | |
| Durability of operational reliability, electrical stability | 8.3.20 | PASS | |
| The products covered by this standard are assumed to enter the alarm condition, in an event of fire, before the fire becomes so large as to affect their functioning. There is therefore no requirement to function when exposed to direct attack from fire. | | | |
| ^(a) Only applicable to components required to indicate loss of communication or to transmit this information to the CIE. | | | |
| ^(b) Not applicable for CIE | | | |
| ^(c) Only applicable for CIE and smoke detectors | | | |

The performance of the products identified in point 1 in conformity with the declared performance in the point 8. This declaration is issued under the sole responsibility of the manufacturer identified in point 3.

La prestazione dei prodotti individuati al punto 1 è conforme alla prestazione dichiarata al punto 8. Tale dichiarazione è rilasciata sotto l'esclusiva responsabilità del fabbricante individuato al punto 3.

This document is available on website: www.argussecurity.it (section download for each product)

Questo documento è disponibile sul sito: www.argussecurity.it (nella sezione "download" di ogni prodotto)

Signed for and on behalf of the manufacturer by:

Firmato a nome e per conto del Fabbrikante da:



Technical Director
Mauro Ceppa

Trieste, Italy

01/09/2022