

## BRE Global

### UK Approved Body No. 0832

BRE Global Limited  
Bucknalls Lane, Garston, Watford,  
Hertfordshire, UK, WD25 9XX  
Telephone: +44 (0) 333 321 8811  
Fax: +44 (0)1923 664603  
Email: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)  
Web: [www.breglobal.com](http://www.breglobal.com)

## Certificate of UKCA approval constancy of performance 0832-UKCA-CPR-F0485

In compliance with the Construction Product Regulations 2020, UK Statutory Instruments 2020 No.1359 of Ministry of Housing, Communities and Local Government. This certificate applies to the construction product.

### S1000 Conventional Photoelectric Smoke Detector

(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trademark of: and produced in the manufacturing plant(s):

Argus Security S.r.l  
Via del Canneto 14  
Valle delle Noghere  
34015 Muggia  
Trieste  
Italy

Argus Security S.r.l  
Via del Canneto 14  
Valle delle Noghere  
34015 Muggia  
Trieste  
Italy

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

### EN 54-7:2018 - Smoke detectors - Point smoke detectors

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

### the constancy of performance of the construction product.

This certificate was first issued on 08 November 2021 and will remain valid as long as neither the designated standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the approved product certification body.



P. Halligan, Technical Manager

On behalf of BRE Global Limited

Date of First Issue: 08 November 2021

Issue Date: 25 August 2022

Issue Number: 02

To check the validity of this certificate, please contact us on +44 (0)333 321 8811 or email [enquiries@breglobal.com](mailto:enquiries@breglobal.com)

**BRE Global**

**UK Approved Body No. 0832**

BRE Global Limited  
Bucknalls Lane, Garston, Watford,  
Hertfordshire, UK, WD25 9XX  
Telephone: +44 (0) 333 321 8811  
Fax: +44 (0)1923 664603  
Email: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)  
Web: [www.breglobal.com](http://www.breglobal.com)

**APPENDIX to Certificate of constancy of performance: 0832-UKCA-CPR-F0485**

**S1000 Conventional Photoelectric Smoke Detector**

**Bases:**

UB100	Universal adaptor base
DBS100	Deep adaptor base
UBR100	Universal adaptor base with resistor
DBSR100	Deep adaptor base with resistor
UBDR100	Universal adaptor base with resistor and Schottky diode
DBSRD100	Deep adaptor base with resistor and Schottky diode



P. Halligan, Technical Manager

On behalf of BRE Global Limited

Date of First Issue: 08 November 2021

Issue Date: 25 August 2022

Issue Number: 02

To check the validity of this certificate, please contact us on +44 (0)333 321 8811 or email [enquiries@breglobal.com](mailto:enquiries@breglobal.com)