

# **BRE Global Ireland**

#### Notified Body No. 2831

BRE Global Assurance (Ireland) Limited DCU Alpha, Old Finglas Road Glasnevin, Dublin, D11 KXN4 Ireland T: +353 (0) 18824344 E: <u>enquiries@breglobalireland.ie</u> www.breglobalireland.ie

## **Certificate of constancy of performance**

### 2831-CPR-F0043

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

#### ALBLS100-32 Altair Addressable Type A Sounder Base (For full product details and conditions of use refer to appendix)

Placed on the market under the name or trade mark of:

Argus Security S.r.I. Via del Canneto 14 Valle delle Noghere Trieste 34015 Muggia Italy and produced in the manufacturing plant(s):

Argus Security S.r.I. Via del Canneto 14 Valle delle Noghere Trieste 34015 Muggia Italy

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 54-3:2001 + A1:2002 + A2:2006 - Sounders

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

### the constancy of performance of the construction product.

This certificate was first issued on 17 October 2019 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

P. Halligan.	Date of First Issue:	17 October 2019
P. Halligan, Certification Engineer	Date of Issue:	17 October 2019
On behalf of BRE Global Assurance (Ireland) Limited	Issue number	01

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie.

bre		
BRE Global Ireland		Notified Body No. 2 BRE Global Assurance (Ireland) Lir DCU Alpha, Old Finglas F Glasnevin, Dublin, D11 K Ire T: +353 (0) 1882 E: <u>enquiries@breglobalirela</u> www.breglobalirela
	0004.05	
APPENDIX to Certificate of constancy of perfor ALBLS100-32 Altair Addressable Type A Sounde		R-F0043
ALBES 100-52 Altan Addressable Type A Sounde		
<ul> <li>Note:</li> <li>1. Meets the requirements of EN 54-3 at the for Tone 1 - Dual Tone 800Hz and 960Hz, 250r Tone 2 – Continuous Tone, 1000Hz, Steady Tone 4 – Slow Whoop, 500-1200Hz, 3500m Tone 5 – Sweep (DIN) Tone, 1200-500Hz, 7</li> <li>2. The sounder base can also be used with the for LID100-AL/W or LID100-AL-R</li> </ul>	ms-250ms / is Sweep, 500ms OF 1s sweep (1Hz)	F
Charligan.	Date of First Issue:	17 October 2019
P. Halligan, Certification Engineer,	Date of issue:	17 October 2019
-		