

## BRE Global Ireland

**Notified Body No. 2831**  
BRE Global Assurance (Ireland) Limited  
DCU Alpha, Old Finglas Road  
Glasnevin, Dublin, D11 KXN4  
Ireland  
T: +353 (0) 18824344  
E: [enquiries@breglobalireland.ie](mailto:enquiries@breglobalireland.ie)  
[www.breglobalireland.ie](http://www.breglobalireland.ie)

## Certificate of constancy of performance

### 2831-CPR-F0649

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

#### S3500 Conventional Category P Heat Detector

*(For full product details and conditions of use refer to appendix)*

Placed on the market under the name or trade mark of:

and produced in the manufacturing plant(s):

**Argus Security S.r.l**  
**Via del Canneto 14**  
**Valle delle Noghere**  
**34015 Muggia**  
**Trieste**  
**Italy**

**Argus Security S.r.l**  
**Via del Canneto 14**  
**Valle delle Noghere**  
**34015 Muggia**  
**Trieste**  
**Italy**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

#### EN 54-5:2017 + A1:2018 - Heat detectors - Point heat detectors

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

### the constancy of performance of the construction product.

This certificate was first issued on 17 October 2019 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.



P. Halligan, Certification Engineer

Date of First Issue: 17 October 2019

Date of Issue: 25 August 2022

On behalf of BRE Global Assurance (Ireland) Limited

Issue number 02

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email [enquiries@breglobalireland.ie](mailto:enquiries@breglobalireland.ie).

**BRE Global Ireland****Notified Body No. 2831**

BRE Global Assurance (Ireland) Limited  
DCU Alpha, Old Finglas Road  
Glasnevin, Dublin, D11 KXN4  
Ireland  
T: +353 (0) 18824344  
E: [enquiries@breglobalireland.ie](mailto:enquiries@breglobalireland.ie)  
[www.breglobalireland.ie](http://www.breglobalireland.ie)

**APPENDIX to Certificate of constancy of performance: 2831-CPR-F0649****S3500 Conventional Category P Heat Detector****Note:**

1. Meets the requirements of EN 54-5 for Category A1R and Category B

**Base:**

UB100	Universal adaptor base
DBS100	Deep adaptor base
UBR100	Universal adaptor base with resistor
DBSR100	Deep adaptor base with resistor
UBDR100	Universal adaptor base with resistor and Schottky diode
DBSRD100	Deep adaptor base with resistor and Schottky diode



P. Halligan, Certification Engineer,

On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 17 October 2019

Date of issue: 25 August 2022

Issue number: 02

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email [enquiries@breglobalireland.ie](mailto:enquiries@breglobalireland.ie).