

BRE Global Ireland

Notified Body No. 2831

BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland
T: +353 (0) 18824344
E: enquiries@breglobalireland.ie
www.breglobalireland.ie

Certificate of constancy of performance 2831-CPR-F2681

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

LW-DMCO-01 Libra Wireless Addressable Multi Criteria Smoke, Heat and CO Detector (For full product details and conditions of use refer to appendix)

Placed on the market under the name or trade mark of:

and produced in the manufacturing plant(s):

Argus Security Srl Via del Canneto 14 Valle delle Noghere 34015 Muggia Trieste

Italy

Argus Security Srl Via del Canneto 14 Valle delle Noghere 34015 Muggia Trieste Italy

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 54-5:2017 + A1:2018 - Heat detectors - Point heat detectors EN 54-7:2018 - Smoke detectors - Point smoke detectors EN 54-25:2008 - Components using Radio Links

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

the constancy of performance of the construction product.

This certificate was first issued on 21 September 2020 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Date of First Issue: 21 September 2020

P Halligan, Certification Engineer Date of Issue: 25 August 2022

On behalf of BRE Global Assurance (Ireland) Limited Issue number 02

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie

BF1938i Rev.1.0 Page 1 of 2 © BRE Global Assurance (Ireland) Limited, 2022



BRE Global Ireland

Notified Body No. 2831

www.breglobalireland.ie

BRE Global Assurance (Ireland) Limited DCU Alpha, Old Finglas Road Glasnevin, Dublin, D11 KXN4 Ireland T: +353 (0) 18824344 E: enquiries@breglobalireland.ie

APPENDIX to Certificate of constancy of performance: 2831-CPR-F2681

LW-DMCO-01 Libra Wireless Addressable Multi Criteria Smoke, Heat and CO Detector

Notes:

- 3. Meets the requirements of EN 54-5 depending on the specific classification setting at Categories A1R and BS.
- 4. Meets the requirements of EN 54-7 at all Category settings.

Category Settings:

- L0 Harsh smoke profile; smoke profile number 0; heat Category BS.
- L1 Harsh smoke profile; smoke profile number 1; heat Category A1R.
- L2 Harsh smoke profile; smoke profile number 2; heat Category A1R.
- L3 Harsh smoke profile; smoke profile number 3; heat Category A1R.
- NO Normal smoke profile; smoke profile number 0; heat Category A1R.
- N1 Normal smoke profile; smoke profile number 1; heat Category A1R.
- N2 Normal smoke profile; smoke profile number 2; heat Category A1R.
- N3 Normal smoke profile; smoke profile number 3; heat Category A1R.
- H0 Clean smoke profile; smoke profile number 0; heat Category A1R.
- H1 Clean smoke profile; smoke profile number 1; heat Category A1R.
- H2 Clean smoke profile; smoke profile number 2; heat Category A1R.
- H3 Clean smoke profile; smoke profile number 3; heat Category A1R.

Base

WAB100 Base

Date of First Issue: 21 September 2020

P Halligan, Certification Engineer, Date of issue: 25 August 2022

On behalf of BRE Global Assurance (Ireland) Limited Issue number: 02

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie