

CPR - DECLARATION of PERFORMANCE

N° AT5010CPR (Conformity EU 305/2011)

1. Unique identification code of the product type:

**A1000L
A2000L
A3500L**

2. Type, batch or serial number or any other element allowing identification of the construction product as required under article 11(4) of the CPR:

**A1000L ALTAIR Lite - Analogue Addressable Photoelectric Smoke Detector
A2000L ALTAIR Lite - Addressable Multi-criteria Detector
A3500L ALTAIR Lite - Analogue Addressable Class P Heat Detector**

3. Intended use or uses of the construction product, in accordance with the applicable harmonized technical specification, as foreseen by the manufacturer:

For use in compatible fire detection and alarm system

4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required under article 11(5):

**ARGUS SECURITY Srl
Via del Canneto 14
Valle delle Noghere
34015 Muggia - Trieste – Italy
info@argussecurity.it www.argussecurity.it**

5. Where applicable, name and contact address of the authorised representative whose mandate covers the tasks specified in article 12(2):

N/A

6. System or systems of assessment and verification of constancy of performance of the construction product as set out in CPR, Annex V:

System 1

7. In case of the declaration of performance concerning a construction product covered by harmonized standard:

**A2000L – A3500L: EN 54-5:2000+A1:2002
A1000L – A2000L: EN 54-7:2000+ A1:2002+A2:2006
A2000L: CEA 4021:2003**

Bre Global Assurance (Ireland) Ltd, N.B. No. 2831, performed the necessary initial inspection of the manufacturing plant and the factory production control together with ongoing continuous surveillance and issued the certificate confirming constancy of the conformity of the factory production control

Product number	LPCB Number	CPR Number
A1000L	928e/03	2831-CPR-F0208
A2000L	928f/02	2831-CPR-F0209
A3500L	928d/03	2831-CPR-F0210

8. In case of the declaration of performance concerning a construction product for which a European Technical Assessment has been issued:

N/A

9. Declared performance:

ESSENTIAL CHARACTERISTICS	CLAUSE APPLICABLE	PERFORMANCE	HARMONISED STANDARD
Nominal activation conditions / Sensitivity, Response delay (response time) and Performance under fire conditions	4.2, 4.3, 5.2 to 5.6, 5.8, 6.2 (Suffix R)	PASS	EN 54-5:2000+A1:2002
Operational reliability	4.4 to 4.11	PASS	
Tolerance to supply voltage	5.7	PASS	
Durability of operational reliability and response delay; temperature resistance	5.9, 5.10	PASS	
Durability of operational reliability; vibration resistance	5.14 to 5.17	PASS	
Durability of operational reliability; humidity resistance	5.11, 5.12	PASS	
Durability of operational reliability; corrosion resistance	5.13	PASS	
Durability of operational reliability; electrical stability	5.18	PASS	
Nominal activation conditions / Sensitivity, Response delay (response time) and Performance under fire conditions	4.8, 5.2, 5.3, 5.4, 5.6, 5.7, 5.18	PASS	EN 54-7:2000+A1:2002+A2:2006
Operational reliability	4.2 to 4.7, 4.9 to 4.11	PASS	
Tolerance to supply voltage	5.5	PASS	
Durability of operational reliability and response delay; temperature resistance	5.8, 5.9	PASS	
Durability of operational reliability; vibration resistance	5.13 to 5.16	PASS	
Durability of operational reliability; humidity resistance	5.10, 5.11	PASS	
Durability of operational reliability; corrosion resistance	5.12	PASS	
Durability of operational reliability; electrical stability	5.17	PASS	

10. The performance of the products identified in points 1 and 2 are in conformity with the declared performance in the point 9. This declaration is issued under the sole responsibility of the manufacturer identified in point 4.



Signed for and on behalf of the manufacturer by:

Charles Lombard – Managing Director – Argus Security Srl, Trieste - ITALY

Trieste, 01 November 2019



Charles Lombard
Managing Director