

CPR - DECLARATION of PERFORMANCE

N° AT5210CPR (Conformity EU 305/2011)

1. Unique identification code of the product type:

ALBS100-32

2. Type, batch or serial number or any other element allowing identification of the construction product as required under article 11(4) of the CPR:

ALBS100-32 – Conventional indoor Type A sounder base

3. Intended use or uses of the construction product, in accordance with the applicable harmonized technical specification, as foreseen by the manufacturer:

For use in compatible fire detection and alarm system

4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required under article 11(5):

ARGUS SECURITY Srl
Via del Canneto 14
Valle delle Noghere
34015 Muggia - Trieste – Italy
info@argussecurty.it www.argussecurty.it

5. Where applicable, name and contact address of the authorised representative whose mandate covers the tasks specified in article 12(2):

N/A

6. System or systems of assessment and verification of constancy of performance of the construction product as set out in CPR, Annex V:

System 1

7. In case of the declaration of performance concerning a construction product covered by harmonized standard:

EN 54-3: 2001 + A1:2002 + A2:2006

Bre Global Assurance (Ireland) Ltd, N.B. No. 2831, performed the necessary initial inspection of the manufacturing plant and the factory production control together with ongoing continuous surveillance and issued the certificate confirming constancy of the conformity of the factory production control

**Certificate N. 928w/02 2831-CPR-F0263
(X-Listing from Cranford Controls Ltd Cert. N. 546a/04 2831-CPR-F0095 for VSO-32E).**

8. In case of the declaration of performance concerning a construction product for which a European Technical Assessment has been issued:

N/A

9. Declared performance:

| ESSENTIAL CHARACTERISTICS | CLOSE APPLICABLE | PERFORMANCE | HARMONISED STANDARD |
|--|-------------------------|--------------------|---------------------------------------|
| Performance under fire conditions | 4.2, 4.3, 5.2, 5.3 | PASS | EN 54-3: 2001 + A1:2002; + A2:2006 |
| Operational reliability | 4.4, 4.5, 4.6, 5.4 | PASS | |
| Durability of operational reliability, temperature resistance | 5.5, 5.7, 5.8, 5.9 | PASS | |
| Durability of operational reliability, humidity resistance | 5.8, 5.9 | PASS | |
| Durability of operational reliability, corrosion resistance | 5.11 | PASS | |
| Durability of operational reliability, shock and vibration resistance | 5.12 to 5.15 | PASS | |
| Durability of operational reliability, electrical stability | 5.16 | PASS | |
| Durability of operational reliability, resistance to ingress | 5.17 | PASS | |

10. The performance of the products identified in points 1 and 2 are in conformity with the declared performance in the point 9. This declaration is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of the manufacturer by:

Charles Lombard – Managing Director – Argus Security Srl, Trieste - ITALY

Trieste, 01 November 2019


Charles Lombard
 Managing Director