



**Argus Security S.r.l.**  
Via del Canneto, 14  
34015 - Muggia (TS) - Italy  
info@argussecurity.it

## UK Declaration of Performance - DoP

Declaration in accordance to (UK) Construction Products Regulation No 305/2011

### *UK Dichiarazione di Prestazione - DoP*

Dichiarazione in conformità al regolamento sui prodotti da costruzione (Regno Unito) n. 305/2011

**N°: VE1910UK**

#### 1. Unique identification code of the product-type:

Codice di identificazione unico del prodotto-tipo:

**Product type:** Short-circuit Isolators

**Model Number and Description:** LVMX100 - VEGA - Addressable Short Circuit Isolator Module

#### 2. Intended use/es:

Usi previsti:

**Fire Safety**

Sicurezza Antincendio

#### 3. Manufacturer:

Fabbricante:

**ARGUS SECURITY Srl**

Via del Canneto 14

Valle delle Noghère - 34015 Muggia - Trieste - Italy

[info@argussecurity.it](mailto:info@argussecurity.it)

[www.argussecurity.it](http://www.argussecurity.it)

#### 4. Authorised representative:

Mandatario:

**Halma UK DS LTS**

Misbourne Court, Rectory Way, Amersham

Bucks HP7 0DE, UK

#### 5. System/s of AVCP:

Sistemi di VVCP:

System 1

#### 6. Designated standard(s):

Norme Indicate:

EN 54-17: 2005

#### 7. UK Approved Body/ies

Organismi Approvati dalla UK

**BRE Global Assurance (Ireland) Ltd, No. 0832**

Product code:

**LVMX100**

CoP Reference:

**0832-UKCA-CPR-F1014**

## 8. Declared performance/s:

Prestazioni Dichiarate:

ESSENTIAL CHARACTERISTICS	CLAUSE APPLICABLE	PERFORMANCE	DESIGNATED STANDARD
Performance parameters under fire conditions	5.2 <sup>(1)</sup>	PASS	EN 54-17:2005
Operational reliability	4	PASS	
Durability of operational reliability, temperature resistance	5.4, 5.5	PASS	
Durability of operational reliability, vibration resistance	5.9 to 5.12	PASS	
Durability of operational reliability, humidity resistance	5.6, 5.7	PASS	
Durability of operational reliability, corrosion resistance	5.8	PASS	
Durability of operational reliability, electrical stability	5.3, 5.13	PASS	

<sup>(1)</sup> This is assuming that the effect of the fire is to cause a short circuit in the transmission path that is protected by these devices

The performance of the products identified in point 1 in conformity with the declared performance in the point 8. This declaration is issued under the sole responsibility of the manufacturer identified in point 3.

La prestazione dei prodotti individuati al punto 1 è conforme alla prestazione dichiarata al punto 8. Tale dichiarazione è rilasciata sotto l'esclusiva responsabilità del fabbricante individuato al punto 3.

This document is available on website: [www.argussecurity.it](http://www.argussecurity.it) (section download for each product)

Questo documento è disponibile sul sito: [www.argussecurity.it](http://www.argussecurity.it) (nella sezione "download" di ogni prodotto)

Signed for and on behalf of the manufacturer by:

Firmato a nome e per conto del Fabbricante da:



---

Technical Director  
Mauro Ceppa

Trieste, Italy

01/09/2021